



CITY OF EASTVALE
COMMUNITY ENHANCEMENT AND SAFETY
DEPARTMENT, BUILDING AND SAFETY DIVISION
 12363 Limonite Avenue, Suite 910
 Eastvale, CA 91752
 951.703.4450
<http://Eastvaleca.gov/building-safety-division>

ALARM VERIFICATION

SECTION

FORM NUMBER

EFFECTIVE DATE

REVISION DATE

Carbon Monoxide Alarm Verification

The California Residential Code requires the installation of carbon monoxide detectors in existing dwellings when alterations, repairs or additions with a valuation exceeding \$1000.00 are made.

These alarms must be installed in the immediate vicinity of the bedrooms and on each level of the residence. These alarms must be installed in accordance with the alarm manufacturer's installation instructions. Battery-only type alarms must be equipped with a 10-year battery and have a silence feature.

I have read and understand the above requirements and affirm by my signature that all required alarms mentioned above have been properly installed and tested.

 Property Address

 Permit #

 Print Property Owner's Name

 Signature of Property Owner

 Date

Attention Property Owner:

This is a voluntary self-certification verification procedure. If you prefer to have a building inspector perform the verification, it must be performed at the time of the final inspection for your project. You must also arrange to have an adult present at the time of the inspection and provide access to the alarms.